

BUILDING NAME	ADDRESS	OPER. SEASON	ORIGINAL AGE	STATUS	TYPE	TOTAL HP	COMPRESSORS					PUMP DETAILS			CAPITAL IMPROVEMENTS
							40hp	50hp	60hp	75hp	100hp	Type	Pump 1	Pump 2	
TEY & WATERFRONT															
Alexandra Park - A.I.R. Bldg (Harry Gairey)	275 Bathurst St	Nov - Mar	6-Mar-58	Good	Double	200 hp	0	1	0	2	0	Glycol	40 hp	20 hp	New slab, header trench and lights Refrigeration system 2006
Ryerson Park - A.I.R. Bldg	25 Gould St	Nov - Mar	Dec-77	Good	Pleasure	150 hp	0	3	0	0	0	Glycol	30 hp	10 hp	Refrigeration system and floor 1997
Regent Park South - A.I.R. Bldg	591 Dundas St E	Nov - Mar	Feb-72	Good	Single	100 hp	0	2	0	0	0	Glycol	20 hp	7.5 hp	Refrigeration system and boards 2000
Nathan Phillips Square - A.I.R. Bldg	100 Queen St W	Oct - Mar	Nov-68	Good	Pleasure	150 hp	0	0	0	2	0	Brine	40 hp	40 hp	Refrigeration system and floor 1991
Sherbourne Commons - A.I.R. Bldg*	61 Dockside Rd	Nov - Mar	Dec-10	Good	Pleasure	40 ton refrigeration system					Brine	10 hp	n/a	Refrigeration system and floor 2010	
Dieppe Park - A.I.R. Bldg	455 Cosburn Ave	Nov - Mar	Nov-74	Good	Single	180 hp						Glycol	40 hp	25hp	New Refrigeration system and boards 2013
Hodgson - A.I.R. Bldg	276 Davisville Ave	Nov - Mar	Jan-81	Good	Double	180hp						Glycol	30 hp	n/a	Refrigeration system and boards 2014
Rosedale Park - A.I.R. Bldg	20 Scholfield Ave	Nov - Mar	Dec-54	Good	Single	100 hp						Glycol	20 hp	7.5 hp	Refrigeration system and boards 1998
Campbell Avenue Playground - A.I.R. Building	225 Campbell Avenue	Nov - Mar	20-Jan-67	Good	Single	100 hp	0	2	0	0	0				2 new compressors 1992, slab, boards and chiller 2002
Cedarvale Park															
Christie Pits (Willowvale) - A.I.R. Building	750 Bloor Street West	Nov - Mar	Dec-78	Good	Single	100 hp	0	2	0	0	0				Refrigeration system and boards 2001
Dufferin Grove - A.I.R. Building	875 Dufferin Street	Nov - Mar	1960's	Good	Double	150 hp	0	0	0	2	0				Refrigeration system and boards 1994
Trinity Bellwoods Park - A.I.R. Building	709 Queen Street West	Nov - Mar	Dec-63	Fair	Single	100 hp	0	2	0	0	0				Refrigeration system and boards 2000
Wallace Emerson C.R.C. - A.I.R. Building	1260 Dufferin Street	Nov - Mar	Nov-81	Good	Double	200 hp	0	0	0	0	2				Refrigeration system and floor 2006
Greenwood Park - Swimming Pool/A.I.R. Bldg	150 Greenwood Ave	Nov - Mar	1960s	Good	Double	180hp	0	0	3	0	0	Glycol	30 hp	30 hp	Refrigeration system and boards 2012
Kew Gardens - A.I.R. Bldg*	2075 Queen St E	Nov - Mar	Dec-54	Fair	Single	150 hp	0	0	0	2	0	Brine	15 hp	15 hp	Retrofit 1983, 2 compressors 1991, condenser 1989
Jimmie Simpson C.R.C. - A.I.R. Bldg	870 Queen St E	Nov - Mar	Nov-70	Fair	Single	100 hp	0	2	0	0	0	Brine	25 hp	25 hp	Refrigeration system and boards 1991
Monarch Park - Swimming Pool/A.I.R. Bldg	115 Felstead Ave	Nov - Mar	Dec-60	Good	Single	100 hp	0	2	0	0	0	Glycol	20 hp	7.5 hp	Refrigeration system and boards 1999
Withrow Park - A.I.R. Bldg	725 Logan Ave	Nov - Mar	1960's	Fair	Single	100 hp	0	2	0	0	0	Brine	25 hp	25 hp	Refrigeration system and boards 1992
WEST REGION															
Buttonwood A.I.R. (Ward 4)	30 Mulham Pl	Dec - Feb	1976	poor		75 hp	0	0	0	1	0	Ammonia	25		Compressor / condenser 1976, Chiller 2004, Header & main 1990
Col Sam Smith A.I.R. (Ward 6)	3145 Larkeshore Blvd	Nov - Mar	2010	excellent		150hp	0	0	0	2	0	Ammonia	30		Refrigeration system 2010
Giovanni Caboto A.I.R. (Ward 17)	1367 St. Clair Ave W	Nov - Mar	1998	excellent		200 hp	0	1	0	2	0	Ammonia	25	15	Refrigeration system and boards 1998
High Park A.I.R. (Ward 13)	1873 Bloor St W	Nov - Mar	1992	poor		200 hp	0	1	0	2	0	Ammonia	25	25	Condenser & header 2015, refrigeration system unknown, boards 2009
Humber Valley A.I.R. (Ward 4)	50 Anglesey Blvd	Dec - Feb	1984/98	good		125hp	0	1	0	1	0	Ammonia	20	7.5	Condenser 1983 poor, heat exchanger & compressor 2 1997
Lambton/Kingsway A.I.R. (Ward 5)	37 Marquis Ave	Dec - Feb	2008	excellent		100 hp	0	0	0	0	1	Ammonia	25		Refrigeration system 2010
West Deane/Martingrove (Ward 3)	400 Martingrove Rd	Nov - Mar	1999	good		100 hp	0	2	0	0	0	Ammonia	20	7.5	Refrigeration system 1998, boards 2015
Prince of Wales A.I.R. (Ward 6)	1 Third St	Dec - Feb	1998	good/poor		100 hp	0	2	0	0	0	Ammonia	20	7.5	refrigeration system 1998, boards 2013, New header and slab 2016
Rennie A.I.R. (Ward 13)	1A Rennie Terr.	Nov - Mar	1997	good		200 hp	0	1	0	2	0	Ammonia	30	25	Refrigeration system 1996, boards 2016
Rivercrest A.I.R. (Ward 2)	30 Harefield Dr	Dec - Feb	1974	poor		75 hp	0	0	0	1	0	Ammonia	25		Refrigeration system 1974
Royalcrest A.I.R. (Ward 1)	50 Cabernet Cir	Nov - Mar	1984	poor		75 hp	0	0	0	1	0	Ammonia	25		Refrigeration system 1984 New refrigeration scheduled and slab scheduled for 2017
Sir Adam Beck A.I.R. (Ward 6)	55 Eltham Dr	Nov - Mar	unkown	poor		100 hp	0	0	0	1	0	Ammonia	25		Condenser, compressor unkown, heat exchanger 1997, headers 2007
Summerlea A.I.R. (Ward 2)	2 Arcot Blvd	Dec - Feb	1973	poor		75 hp	0	0	0	1	0	Ammonia	25		Refrigeration system 1973 New refrigeration system and slab scheduled for 2018
Sunnydale A.I.R. (Ward 2)	50 Amaro Dr	Nov - Mar	2000	excellent		100 hp	0	2	0	0	0	Ammonia	20	7.5	Condenser 1989, coppersors and heat exchanger 2000
Valleyfield A.I.R. (Ward 4)	35 The Westway	Nov - Mar	1972	poor		80 hp	1	1	0	0	0	Freon	20		New refrigeration system and slab scheduled for 2016
Wedgewood A.I.R. (Ward 5)	15 Swan Ave	Dec - Feb	2003	excellent		100 hp			2	0	0	Ammonia	25		Refrigeration system 2003 New slab scheduled for 2016
West Mall A.I.R. (Ward 3)	370 The West Mall	Nov - Mar	1999	excellent		200 hp	0	0	0	0	2	Ammonia	30	25	Refrigeration system 1999, boards 2007
Westgrove A.I.R. (Ward 4)	15 Redgrave Dr	Dec - Feb	1976	poor		75 hp	0	0	0	1	0	Ammonia	25		New Refrigeration system and slab scheduled for 2016
Westway A.I.R. (Ward 4)	175 The Westway	Nov - Mar	1997	good		100 hp	0	2	0	0	0	Ammonia	20	7.5	Refrigeration system and boards 1997
Joseph Bannon A.I.R. (Ward 7)	65 Mary Chapman	Dec - Feb	2002	excellent		HVAC type system					Freon	20		Refrigeration system and slab 2013	
NORTH REGION															
Otter creek Park - A.I.R. Bldg - belongs to North district	140 Cheritan Ave	Nov - Mar	Dec-76	Good	Double	200 hp						Glycol	40 hp	10 hp	Refrigeration system and boards 2001
Ramsden Park - A.I.R. Bldg	1020 Yonge St	Nov - Mar	Dec-54	Good	Double	200 hp						Brine	25 hp	25 hp	New rink 1979, New Ammonia system 1991
Broadlands	19 Castle Grove Blvd.	Nov - Mar	2006	Good	Double	100 hp	0	2	0	0	0	Brine	25 hp		Refrigeration system and boards (Installation 1999)
Glen Long	35 Glen Long Ave		1963	Fair	Double	100 hp	0	2	0	0	0	Brine	20 hp		Refrigeration system and boards (Installation 1998)
Irving W, Chapley	205 Welmington Ave	Nov - Mar	2002	Good		100 hp	0	2	0	0	0	Brine	20 hp	0	Refrigeration system and boards (Installation 1998)
North Toronto Memorial CC	200 Eglinton Ave. W.	Nov - Mar	1960	poor		200 hp	0	1	0	2	0	Brine	30 hp	30 hp	Refrigeration system and boards plus Pleasure Pad (Installation 2010)
Ledbury	160 Ledbury St.	Nov - Mar	1997	Good		100 hp	0	2	0	0	0	Brine	15 hp	15 hp	Refrigeration and Pleasure (Installation 1987)
Mel Lastman Square	5100 Yonge St.	Nov - Mar	1998	Fair		80 hp	2	0	0	0	0	Freon	15 hp		Refrigeration and Pleasure (Installation 1988)
Pleasantview	545 Van Horne Ave	Nov - Mar	1975	Good		110 hp						Glycol	15 hp	0	Pleasure, 2-30 hp compressor plus 1-50 (Installation 1995)
* Indicates Freon Refrigeration Plants															
** Ammonia pumps direct expansion floor															